

ATTACHMENT 4 – ASSET CONDITION CODES

Asset Condition is category A

A01	Cut out currently operating hot (signs of overheating)	
A02	Service Cable currently operating hot	
A03	Defective/weakened fuse carrier contacts	
A04	Physical damage to cut out/service cable requiring immediate action	
A05	Visual indication of burning/smell of smoke/smoke	
A06	Audible sounds of arcing	
A07	Exposed live conductors (live or neutral)	
A08	Broken fuse carrier – access to live components	
A09	Exposed conductors – evidence of theft/vandalism/damage	
A10	DNO Earthing issues which present an immediate risk to Consumer/MO	
A11	Disconnected or severely damaged DNO earth terminal/protective conductor	
A12	Currently damaged and exposed asbestos components including meter boards	
A13	Visible possible airborne asbestos fibres present at the service position	
A14	Polarity identified as incorrect at DNO cut out	
A15	Immediate risk to the public or customer due to current service position location	
A16	Service position insecure and exposed to immediate weather damage	
A17	Risk of electric shock or electrocution	
A18	Risk of fire at service position	

Asset Condition is category B

B01	Fuse Carrier welded in to cut out base	
B02	Cut out loose on meter board	
B03	Damaged/missing phase barriers	
B04	Damaged/broken cut out terminals - missing terminal screws	
B05	Non With-drawable fuses by design	
B06	Cut Out unable to accept 16mm meter tails	
B07	Meter tails need to be replaced but cannot be changed by competent staff	
B08	Unhinged metal cut out covers over un-insulated conductors	
B09	Asbestos boards/materials identified – no immediate risk	

Asset Condition is category C

C01	Signs of overheating – no damage to cut out or premises	
C02	Signs of Bitumen Compound leaking	
C03	Small fuses ie less than 60A	
C04	Concern over phase rotation incorrect at cut out	
C05	Shared fuses/cut outs/neutral blocks	
C06	Metal Clad Cut Out	
C07	Seal Tags Broken on cut out	
C08	Cut out with a fused neutral	
C09	Damaged or missing service cable guard	
C10	Service cable in cavity	
C11	Asbestos barriers, insulation, fuse shields identified	
C12	Excessive vegetation growth	
C13	Unacceptable close proximity to gas service	
C14	Fed from distribution board – local/remote from meters	
C15	VIR/MICC lead in's to property	