

DCUSA Issues Form (DIF)

This form should be used by parties to submit matters for consideration to DCUSA Standing Issues Group (SIG).

The completed form should be issued to DCUSA@electralink.co.uk

Document Control	
Date Submitted	21/09/2011
Issue Title:	Large Whole Current Meters
Issue Number*:	DIF 025
Meeting Ref*:	09/11
Attachments:	AMO paper on issue of large whole current meters

**Assigned by DCUSA Secretariat*

Originator details	
Party Name	British Gas
Originator Name	Kevin Woollard
Party Category	Supplier
Email Address	Kevin.woollard@centrica.co.uk
Telephone Number	07979 563580

Nature of Issue
<p>An issue has arisen associated with the Supplier Licence obligation to install "advanced meters" on all Profile Class 5-8 metered sites by April 2014. The issue arises on sites where there are currently a number of whole current meters installed which have a rating over 100 Amps (typically 160). The issue is that it is no longer possible to procure 160 Amp whole current meters and a solution is required to enable an advanced meter to be installed on these sites.</p> <p>The attached paper from the AMO explains the issue in more detail and discusses the options for resolving the issue.</p> <p>The SIG is asked to review the issue and investigate the various options outlined in the AMO paper.</p>

Solution Overview – if known

Solution description:

Lead time for
Implementation: