



A specialist energy consultancy

F-Factor Impact Analysis

DCP 313 Working Group

DCUSA Ltd

12818-001
27 September 2018

COMMERCIAL IN CONFIDENCE

DCUSA

tneigroup.com

.....

Quality Assurance

TNEI Services Ltd and TNEI Africa (Pty) Ltd. ("TNEI") operates an Integrated Management System and is registered with Ocean Certification Limited as being compliant with ISO 9001(Quality), ISO 14001 (Environmental) and OHSAS 18001 (Health and Safety).

Disclaimer

This document is issued for the sole use of the Customer as detailed on the front page of this document to whom the document is addressed and who entered into a written agreement with TNEI. All other use of this document is strictly prohibited and no other person or entity is permitted to use this report unless it has otherwise been agreed in writing by TNEI. This document must be read in its entirety and statements made within may be based on assumptions or the best information available at the time of producing the document and these may be subject to material change with either actual amounts differing substantially from those used in this document or other assumptions changing significantly. TNEI hereby expressly disclaims any and all liability for the consequences of any such changes. TNEI also accept no liability or responsibility for the consequences of this document being relied upon or being used for anything other than the specific purpose for which it is intended, or containing any error or omission which is due to an error or omission in data used in the document that has been provided by a third party.

This document is protected by copyright and may only be reproduced and circulated in accordance with the Document Classification and associated conditions stipulated or referred to in this document and/or in TNEI's written agreement with the Customer. No part of this document may be disclosed in any public offering memorandum, prospectus or stock exchange listing, circular or announcement without the express and prior written consent of TNEI. A Document Classification permitting the Customer to redistribute this document shall not thereby

imply that TNEI has any liability to any recipient other than the Customer.

Any information provided by third parties that is included in this report has not been independently verified by TNEI and as such TNEI accept no responsibility for its accuracy and completeness. The Customer should take appropriate steps to verify this information before placing any reliance on it.

Document Control

Revision	Status	Prepared by	Checked by	Approved by	Date
R0	FIRST ISSUE	AO	Tan	Tan	27/09/2018

TNEI Services Ltd

Company Registration Number: 03891836

VAT Registration Number: 239 0146 20

Registered Address

Bainbridge House

86-90 London Road

Manchester

M1 2PW

Tel:+44 (0)161 233 4800

Fax:+44 (0)161 233 4801

7th Floor

West One

Forth Banks

Newcastle upon Tyne

NE1 1PA

Tel:+44 (0)191 211 1400

Queens House

19 St. Vincent Place

Glasgow

G1 2DT

Tel:+44 (0)141 428 3180

TNEI Africa (Pty) Ltd

Registered: Mazars House, Rialto Rd, Grand Moorings Precinct, 7441 Century City, South Africa

Company Number: 2016/088929/07

1st Floor

Willowbridge Centre

Carl Cronje Drive

Cape Town

South Africa, 7530

Tel: +27 (0)21 974 6181

Executive Summary

A qualitative assessment has been made of the impact changing an embedded generator F factor may have on customer Charge 1 values and NUF factors. If the F factor of a generator is defined based purely on technology type as suggested in DCP 313 option 2, then generators which were deemed not to contribute to network security and were assigned a zero F factor could be assigned a non-zero F factor. This would have a similar effect as if these generators were added as new generation into the maximum demand scenario model.

In general, adding a new generator may delay the year in which network branches could require reinforcement. Delaying the year of reinforcement would generally reduce customer Charge 1 values in both the LRIC and FCP methodologies.

The amount of any charge reduction would depend on the location of branches, whose reinforcement has been delayed, with respect to customers. For LRIC, this depends on the branches which a nodal demand 'uses', while for FCP it depends on the network group which the nodal demand is in.

In addition to the relative locations of nodal demands, branches and generators, the cost reduction will be influenced by the branch reinforcement cost and reinforcement year. Delaying reinforcement of a more expensive branch or a branch which requires reinforcement in 'early' years will have the greatest impact on costs.

It is possible that adding new generators will have no impact on customer charges. This happens in FCP if the new generators are not large enough to delay branch reinforcement or there are no branches which require reinforcement in the local network area. In LRIC, this happens if the branches with delayed reinforcement are not "used" by the customer.

New generation is more likely to reduce charge 1 values in a demand dominant network than in a generation dominant network.

Adding a new generator does not change the branches 'used' by a nodal demand when calculating NUFs. In demand dominant networks the new generator may decrease the maximum contingency flow on those branches which a nodal demand uses, which may generally decrease NUFs. There is a case, however, where the maximum contingency flow on a demand dominant branch may be increased by the addition of a new generator, which would increase NUFs.

In a generation dominant network adding a new generator may increase the maximum contingency flow on branches used by a nodal demand, which may increase NUFs. The base flow on branches used by the nodal demand, however, may either increase or decrease depending on branch/load/generator locations which would either decrease or increase NUF values correspondingly.

When a new generator alters the maximum contingency flow of a branch the magnitude by which the NUF factor is altered would depend on the size of the change in flow in proportion to the branch rating. Whether a branch NUF allocation increases or decreases in a generation dominated asset would further depend on the magnitude of this change combined with the magnitude of change in 'base flow' compared to 'base flow load'. If the change in flow values is small compared to the branch rating (and existing base flow) then the magnitude change to NUF values will also be small.

Contents

Document Control.....	3
Executive Summary.....	4
Contents.....	5
1 Introduction	7
1.1 What is F Factor	7
1.2 What is DCP 313.....	7
2 LRIC Methodology.....	8
2.1 Impact on Nodal Charge 1 in Demand Dominant Networks	9
2.1.1 The impact of new generation location on network reinforcement time.....	9
2.1.2 The impact of generation location on branch incremental cost and nodal charge.....	11
2.2 Impact on Nodal Charge 1 in Generation Dominant Network	12
3 FCP Methodology.....	13
3.1 Impact on Charge 1 in Demand Dominant Networks.....	14
3.1.1 Potential delay in asset reinforcement year.....	15
3.1.2 Potential reduction in network group charge 1.....	16
3.2 Impact on charge 1 in generation dominant networks	18
3.3 Summary	18
4 NUF Methodology.....	19
4.1 Impact on demand dominant network.....	20
4.1.1 Impact on specific example network	20
4.2 Impact on generation dominant network	22
4.2.1 Impact on specific example network	23
4.3 Summary	26

TABLES

Table 2-1: Changes of reinforcement time of each network branches to different generator location	11
Table 3-1 Potential delay in asset reinforcement in network levels by generation location	16
Table 3-2 Potential impact of new generator in the power flow model on charge 1 by network group	17
Table 4-1 Branches used by hypothetical customers by voltage level	21
Table 4-2 Potential impact maximum contingency flow of branches by voltage level	21
Table 4-3 Branches used by hypothetical customers by voltage level	24
Table 4-4 Potential impact maximum contingency flow of branches by voltage level	25

FIGURES

Figure 2-1: Example of demand dominated network.....	10
Figure 2-2: Example of generation dominated network.....	10
Figure 3-1 Network groups	14
Figure 3-2 Hypothetical demand dominant network	15
Figure 4-1 Demand / generation dominant asset illustration	19
Figure 4-2 Example generation dominant network.....	23

1 Introduction

This assessment has been undertaken in response to a request from the DCP 313 Working Group to provide a generic description of the impact on the charges for a given generator of changing from having a zero F factor assigned to having a non-zero F factor assigned and the likely impact on the charges for other customers connected to the local network. A qualitative assessment has been undertaken on both Long Run Incremental Cost (LRIC) and Forward Cost Pricing (FCP) Extra High Voltage (EHV) Distribution Charging Methodology (EDCM) charging methodologies as well as Network Use Factors (NUF). When considering customer charges the impact has been limited to the customers 'charge 1' value, which is the output of the power flow analysis process and the input to 'Workstream B' calculations.

1.1 What is F Factor

The legal text in schedules 17 and 18 requires Distribution Network Operators (DNOs) to determine an F factor for each EDCM embedded generator based on the criteria set down in Engineering Recommendation P2/6 – 'Security of Supply' (ER P2/6) and Engineering Technical Report 130 – 'Application Guide for Assessing the Capacity of Networks Containing Distributed Generation' (ETR130). The F factor is determined based on generation technology type and a site-specific assessment of the contribution to network security of each EDCM embedded generator, taking into account availability and the operating regime, alongside intermittency.

EDCM embedded generators are deemed to be eligible to receive charge one credits (unit rate credits applicable in the DNO's peak 'super-red' period, calculated based on a power flow analysis of the DNO's network) if they have a non-zero F factor, and are deemed not eligible to receive charge one credits if they have a zero F factor.

1.2 What is DCP 313

DCP 313, is seeking to amend the EDCM to improve transparency in the way in which F factors are assigned to generators for the power flow modelling, and then the criteria by which a given generator will be eligible for credits is determined, which is an input to the EDCM model itself. The reason for the change is that the requirements of P2/6 when setting the F factor rely on data which is only available to the DNO, and there is a concern among generators that different DNOs may be applying different interpretations of P2/6 when determining the F factor to use.

One of the solutions (Option 2) the Working Group is looking at would involve replacing the use of F factors in the power flow modelling with an equivalent factor which would be determined entirely based on the technology type of the generator in question. This will inevitably lead to some generators which currently have a zero F factor changing to have a non-zero F factor and vice versa.

2 LRIC Methodology

The LRIC model calculates a pair of **branch incremental costs**, one for the maximum demand scenario (peak, charge 1) and another for the minimum demand scenario (off-peak, charge 2), for each network branch for an increment of demand or generation in each network node. It uses AC power flow analysis, which calculates the time needed (**years to reinforcement**) before elements of the network require reinforcement, and subsequently the net present value (NPV) of the future costs of reinforcement. The branch incremental cost is equal to the difference in the NPV of reinforcing under existing conditions and when an increment of new demand or generation is added. The **nodal charges** are then calculated by summing all the branch incremental costs. Only branches that experience a change greater than a small kVA and percentage of base power flow thresholds are used in the calculation of nodal charges.

It should be pointed out that each branch incremental cost is considered in just one out of the two charge periods (peak or off-peak but not both) based on the scenario that drives the maximum absolute value of branch incremental cost.

For the maximum demand scenario, the generation export is set to the maximum export capacity (MEC) multiplied by a F Factor. The F factor is set to zero unless it is deemed to contribute to network security in accordance with P2/6. The generation export used for the minimum demand scenario is set to the MEC, factored to reflect coincidence with other EDCM generators within the GSP network group.

If the F factor of a generator is defined based purely on technology type as suggested in DCP 313 option 2, then generators which were deemed not to contribute to network security and were assigned a zero F factor could be assigned a non-zero F factor. This would have a similar effect as if these generators were added as new generation into the maximum demand scenario model. The change of a generator F factor from a zero to non-zero value will have no impact to the branch incremental costs calculated under minimum demand scenario.

2.1 Impact on Nodal Charge 1 in Demand Dominant Networks

For a demand dominated network, the headroom of network branches available for load growth under the maximum demand scenario is usually less than the headroom available under the minimum demand scenario. Branch reinforcement will always be driven by the maximum demand scenario, and hence the corresponding branch incremental cost (charge 1) will always tend to be higher. In addition, a change of F Factor will not affect the branch incremental cost calculated under minimum demand scenario and hence it is logical to exclude the minimum demand scenario when considering the impact on nodal charge 1 in a demand dominant network.

The formulae to calculate branch incremental cost due to an increment at a node and nodal charges are provided in Attachment 1 of the LRIC Methodology Document¹. It can be deduced from the formulae that the most important element affected by the addition of new generation which eventually impact the nodal charges for each customer is the years to reinforcement.

2.1.1 The impact of new generation location on network reinforcement time

Considering the potential new generation locations shown in Figure 2-1, Table 2-1 indicates the network branches which may see a change in reinforcement year due to new generation. In general, the reinforcement year of these network branches either remains unchanged or is delayed in a demand dominated network, depending on the location of the new generator with respect to the network branches. The network may see a delay in reinforcement if the new generator causes a reduction in maximum post contingency flow through the network branch. A reduction in intact flow due to a new generator does not guarantee a delay in network reinforcement.

For the network branches which experience a delay in network reinforcement, the magnitude of delay will depend on the nodal sensitivity factor² of the new generation with respect to the branch under post contingency network configuration. The generator which is connected at a network node with a larger nodal sensitivity factor with respect to the network branch, which results in a greater reduction in post contingency flow, will result in a longer delay in network reinforcement.

However, it should be noted that if it is a very large new generator, which results in a change of power flow direction, and the new power flow magnitude is greater than the magnitude of flow before change, the time of reinforcement calculated for the network branch will decrease (accelerate).

¹ Schedule 18 – EHV Charging Methodology (LRIC Model), Version 10.3

² Nodal sensitivity factor of a branch with respect to a generator node can be defined as the ratio of MVA power flow change on the branch to a MVA injection to the node.

Figure 2-1: Example of demand dominated network




Figure 2-2: Example of generation dominated network




Table 2-1: Changes of reinforcement time of each network branches to different generator location

Branches	Generator Location							
	GSP	Node132	BSP1	BSP2	Node33	PRY1	PRY2	PRY1*
LGSP1								
GT1								
LGSP2								
GT2								
LGSP3								
LBSP1a								
T1a								
LBSP1b								
T1b								
LBSP2a								
T2a								
LBSP2b								
T2b								

* a large generator which result in a change of power flow direction in branch LBSP1a, 1b and T1a,1b

	No Change
	Delay
	Accelerate

2.1.2 The impact of generation location on branch incremental cost and nodal charge

Based on Table 2-1, in which the impact of the generation location on network reinforcement time is summarised the impacts on branch incremental cost can be deduced. By summing the branch incremental costs the impact on the nodal charge can be assessed.

In general, branch incremental cost reduces when the years to reinforcement is delayed. Therefore all the load customers connected at BSP1, BSP2, Pry1 and Pry2 will see a reduction in nodal charges. The impact is wider and the magnitude of nodal charge reduction is higher if the new generator is connected in a lower level network group. For example, a customer connected at Pry1 is likely to see a greater nodal charge reduction with a new generation connected at Pry1 as compared to a new generation (assuming same MEC) at the locations BSP1, BSP2 or Node132. Similarly a customer connected at BSP1 is likely to see a greater nodal charge reduction with a new generation connected at BSP and Primary level as compared to a new generation connected at GSP level.

Apart from the generator locations, it should be noted that the magnitude of branch incremental cost reduction also depends on the cost to reinforce the branch and the years to reinforcement of the branch. If it is an expensive long circuit (e.g. a 20 km overhead line), the reduction of branch incremental cost is high. Similarly, if the years to reinforcement of the branch was small, the impact on branch incremental cost is also high. For example the magnitude of reduction in incremental cost

for a branch which has a reinforcement time delayed from year 1 to year 2 is a lot higher (varies exponentially) than a branch which has a reinforcement time delayed from year 20 to year 21.

Also, a reduction in charge 1 incremental cost for a branch can potentially result in charge 2 becoming dominant (reinforcement of the branch is now driven by minimum demand scenario) and result in charge 1 not being used in the calculation of nodal charges.

2.2 Impact on Nodal Charge 1 in Generation Dominant Network

In a generation dominant network, the majority of the network branch reinforcements are likely to be driven by the minimum demand scenario. As branch incremental cost is only considered in one out of the two charge periods (maximum or minimum demand scenario), it is likely that nodal charge 1 for customers connected in the network is smaller than charge 2 or in some extreme scenario equal to zero. The addition of a new generator in a generation dominated network will either reduce charge 1 further, or in the extreme case it has no impact as charge 1 was already zero in value.

3 FCP Methodology

In FCP, charge 1, is calculated for each network group. Groups are categorised into three levels, the assets associated with each level are as follows:

Level 1 (GSP Group): EHV branches connecting GSPs to BSPs and EHV branches connecting 132 kV busbars in the same GSP group. Black components in Figure 3-1.

Level 2 (BSP Group): BSP transformers and outgoing network group branches. Green components in Figure 3-1.

Level 3 (Primary Group): Primary transformers only. Red components in Figure 3-1.

An incremental charge is calculated for each asset that requires reinforcement during the 10-year planning horizon. If the year in which reinforcement is required is later, the charge for that asset reduces.


The charge 1 value for each group consists of, the sum of the incremental charges for all the assets in that group which need reinforcing during the 10-year planning horizon, plus the charge 1 value of all the higher level groups under which it is a child.

In the network shown in Figure 3-1 the charge for group GSP 1 (a level 1 group) will contain costs associated with asset reinforcements in group GSP 1 only. The charge for group BSP 1 (a level 2 group) will contain costs associated with asset reinforcements in group BSP 1 and group GSP 1, while the charge for group Primary 1 (a level 3 group) will contain costs associated with asset reinforcements in group Primary 1, group BSP 1 and group GSP 1.

Considering customers, customer C1 is connected at a level 1 group and will be assigned charges related to reinforcement costs to network assets in group GSP 1 (black zone). Customer C2 is connected at a level 2 group and will be assigned charges related to reinforcement costs to network assets in group BSP 1 (green zone) **in addition** to charges related to reinforcement costs in its parent level 1 group (i.e. group GSP 1). Customer 3 and customer 4 are connected at level 3 groups and will be assigned charges related to reinforcement cost of the primary transformers supplying their separate primary network groups (red zones) **in addition** to charges related to their parent level 2 and grandparent level 1 groups.

If a generator is defined an F factor based purely on technology type, then generators which may have been assigned zero F factor could be assigned a non-zero F factor. This would have the effect of introducing a new generator in the power flow model. If new generation is introduced in the model, it can be appreciated that the year in which an asset may be overloaded, due to load growth, may be delayed, possibly even beyond the 10-year horizon.

Figure 3-1 Network groups




3.1 Impact on Charge 1 in Demand Dominant Networks

The impact of additional generation on a power flow model group's potential charge depends on two factors:

- Potential delay in asset reinforcement year.
- Potential reduction in network group charge 1.

Figure 3-2 Hypothetical demand dominant network



3.1.1 Potential delay in asset reinforcement year

Firstly, the generators location in the network impacts which assets would see a reduced flow due to network demand. Reducing branch flow due to demand would potentially delay the year in which a branch would require reinforcement due to load growth.

Considering the potential new generator locations shown in Figure 3-2, Table 3-1 indicates the assets (by group) which may see a delayed reinforcement year due to new generation. It could be appreciated that generators which are connected at a particular level are more likely to mitigate reinforcement of assets in that level. For example the reduction of demand flow, compared to asset rating, due to generation connected at location E is likely to be greater for branches in group Primary 1 rather than group GSP 1. The generation at location E may however still reduce flow in the group GSP 1 assets.

Table 3-1 Potential delay in asset reinforcement in network levels by generation location

Generator Location	Network group			
	GSP 1, Level 1	BSP 1, Level 2	Primary 1, Level 3	Primary 2, Level 3
A				
B				
C				
D				
E				

	No Change
	Delay
	Accelerate

3.1.2 Potential reduction in network group charge 1

A network group (and therefore customer) location in relation to a branch whose reinforcement year is delayed impacts whether or not that group charge 1 value may be reduced. Table 3-2 summarises this effect. Since the charge 1 value for a level 3 group includes the reinforcement costs of the parent and grandparent networks under which it is connected, all the generator locations in Figure 3-2, except location A, have the potential to reduce the charge 1 value of every group within the same GSP group. Although no generator may reduce the asset flows in group Primary 2, all generators may reduce flows in the groups GSP 1 or BSP 1 and therefore would impact the charge 1 value of the group. This is described in more detail below:

- **A new generator at location A** may reduce flow on the GSP transformer supplying the network group. Reinforcement of GSP transformers is not considered in EDCM analysis so this would not impact the charges for any customers.
- **A new generator at location B** may reduce flow in the right hand branch supplying the BSP and delay a potential reinforcement to this branch. Delaying the reinforcement of a GSP branch would reduce the charges assigned to customers connected in that GSP group, its child BSP group and its grandchild primary groups, in this example customers in locations C1, C2, C3 and C4. Generators at locations C, D and E may also reduce flow in the 132 kV branches hence also impacting the charge 1 values of these customers.
- **A new generator at location C** may also reduce flow on the BSP transformers supplying the BSP group and delay a potential transformer reinforcement. Delaying the reinforcement of a BSP transformer would reduce the charges assigned to customers connected in that BSP group and its child primary groups, in this example customers in locations C2, C3 and C4. Generators at locations D and E may also reduce flows on the BSP transformers hence also impacting the charge 1 values of customer C2, C3 and C4.

- **A new generator at location D** may also reduce flow on the BSP branch supplying the primary transformer and delay a potential branch reinforcement. Delaying the reinforcement of a BSP branch would reduce the charges assigned to customers connected in that BSP group and its child primary groups. In this example customers in locations C2, C3 and C4. A generator at location E may also reduce flow on the EHV branches supplying the primary transformer it is supplied by, hence also impacting the charge 1 values of customer C2, C3 and C4.
- **A new generator at location E** may also reduce flow on the primary transformers supplying the primary group and delay a potential transformer reinforcement. Delaying the reinforcement of a primary transformer would reduce the charges assigned to customers connected in that primary group. In this example customers in location C3.

Table 3-2 Potential impact of new generator in the power flow model on charge 1 by network group

Generator Location	Network group			
	GSP 1 (Level 1, GSP group 1)	BSP 1 (Level 2, GSP group 1, BSP group 1)	Primary 1 (Level 3, GSP group 1, BSP group 1, Primary group 1)	Primary 2 (Level 3, GSP group 1, BSP group 1, Primary group 2)
A				
B				
C				
D				
E				

	No Change
	Decrease
	Increase

It should be noted that the discussion here refers to potential charge changes. The impact of a new generator on branch flows would be dependent on location, network configuration and the location of existing generator and demand connections. It is entirely possible that a new generator would have no impact on customer charges. For example, if there were no reinforcements identified in a network group before the new generator is added then there would be no reinforcement to delay, or if the new generation is not sufficient to delay a reinforcement then the costs would also remain unchanged.

3.2 Impact on charge 1 in generation dominant networks

The impact of modelling additional generation in a generation dominant network would have a similar high level effect on FCP charge 1 as described in section 3.1 for a demand dominant network. However, the probability of reducing FCP charge 1 in a generation dominant network is likely to be much lower.

It is anticipated that the number of network reinforcements required in a generation dominant network due to load increase over the 10-year load forecast period would be much less, therefore associated cost reductions due to delaying reinforcements would be less. There would have to be a large step-change increase in demand flow in the 10-year demand forecast in order to overload a generation dominant asset due to demand flow.

Should there be a very large decrease in demand, it is possible that an asset may be overloaded due to generation flow, resulting in an increase in the FCP charge 1 figure, however this possibility is considered unlikely.

3.3 Summary

In summary, adding new generation to a network may reduce network group charge 1 values. A generator connected at any level within a network group (except for generator directly connected to a GSP substation) has the potential to decrease charge 1 values for all sub-group levels (1 to 3) within that GSP network group. Generators connected at higher voltage levels (e.g. Level 1) may have a greater impact on group charges than generators connected at lower levels (e.g. Level 3). If no network asset overloads exist in the group in the 10-year planning horizon before the new generation is included then the generator will have no impact on group charge 1 values. Similarly, if the new generation included is not large enough to delay an identified asset overload there will be no impact on charge 1 values.

New generation is more likely to reduce charge 1 values in a demand dominant network than in a generation dominant network.

4 NUF Methodology

A high-level overview of the NUF calculation for a particular nodal demand is as follows:

- Step 1 The network branches which a given nodal demand uses are determined.
- Step 2 The 'MW usage' of each branch by the nodal demand is calculated.
- Step 3 The 'total MW usage' of each branch by all network nodal demands is identified.
- Step 4 The nodal demands proportionate usage of the branches it uses are determined to give an allocation (£/annum).
- Step 5 The (£/annum) value for each branch that the nodal demand uses at each voltage level are summated. The voltage levels are '132 kV', '132 kV/EHV', 'EHV', 'EHV/HV' and '132 kV/HV'. At each level this summated value is then divided by the kW demand at the node to give a (£/kW/annum) value for each voltage level.
- Step 6 The process of steps 1 to step 5 will have been carried out for each CDCM demand node in the network to calculate a (£/kW/annum) figure at each voltage level for each CDCM nodal demand. From these values the average CDCM (£/kW/annum) figure is calculated for each voltage level.
- Step 7 The NUF for the EDCM nodal demand is calculated by dividing the (£/kW/annum) value for each voltage level by the corresponding average CDCM (£/kW/annum).

A variation in generation F factor would impact Step 4 of the NUF calculation, the formula for the (£/annum) calculation for a demand dominated branch is:

$$Alloc (£/year) = \left(\frac{[MWusage]}{[Total MW usage]} \right) * \left(\frac{abs [Max contingency flow]}{[Rating]} \right) * AMEAV$$


For a generation dominated branch the formula is:

$$Alloc (£/year) = \left(\frac{[MWusage]}{[Total MW usage]} \right) * \left(\frac{abs [Max contingency flow]}{[Rating]} \right) * \left(\frac{abs [Base flow load]}{[Base flow]} \right) * AMEAV$$

A network asset is considered to be generation dominant based on the following equation, which is also illustrated in Figure 4-1.

IF: $2 \times abs(base flow load) \leq abs(base flow - base flow load)$ THEN: asset is generation dominant

Figure 4-1 Demand / generation dominant asset illustration



Adding a new generator will not alter the branches which a nodal demand is deemed to use, however it can be appreciated that adding additional generation to the model would affect the “Max contingency flow” and “Base flow” of those assets.

When a new generator alters the maximum contingency flow of a branch the amount by which the NUF factor is altered would depend on the size of the change in flow in proportion to the branch rating. For example a 2 MVA generator connected to the end of a radial 50 MVA rated branch would have a much smaller impact on NUF factors than a 10 MVA generator connected to the end of a radial 15 MVA rated branch.

Modelling additional generation may also have a corresponding impact on calculated CDCM (£/kW/annum) values, however, when averaged across the entire network the impact on the average CDCM values would likely be diluted when compared to the impact on a particular EDCM nodes allocation.

4.1 Impact on demand dominant network

For a demand dominant branch the term $(\text{abs}[\text{Max contingency flow}]/\text{Rating})$ in the allocation equation is the term for which the result could be altered.

Where a new generation impacts the flows on a branch “used” by a nodal demand, it is likely that the “maximum contingency flow” would be reduced, reducing the NUF allocation for that asset to the customers NUF.

It is possible however, to imagine a case where adding a new generation may increase the maximum contingency flow. For example, if a primary group contains more generation than load and is exporting generation to the wider network, even if it is not generation dominant, (e.g. 2nd example in Figure 4-1) adding additional generation in that primary group may increase the maximum contingent flow across the circuits which are exporting the generation.

Thus it is seen that adding a new generation to a network, may either increase or decrease a nodal demands NUF at each voltage level dependant on the relative network locations and existing demand and generation flows in the network.

4.1.1 Impact on specific example network

Considering the demand dominant network shown in Figure 3-2, the impact of adding an additional 3 MW generator illustrated in Table 4-2.

Adding a new generator at location A would not impact the maximum contingency flow on branches.

A new generator at location B may reduce the maximum contingency flow on the right hand side 132 kV branch.

A new generator at location C would reduce the maximum contingency flow in the 132 kV circuits and the 132/EHV transformers. It is not considered that the generator at this location would reduce maximum contingency flow on the EHV branches though, as the maximum contingency flow would be when the right hand side 132 kV branch is outaged.

A new generator at location D would reduce the maximum contingency flow in the 132 kV circuits, the 132/EHV transformers and the EHV circuits supplying demand C4.

A new generator at location E would reduce the maximum contingency flow in the 132 kV circuits, the 132/EHV transformers, the EHV circuits supplying demand C3 and the EHV/HV transformers supplying demand C3.

If a nodal demand customer is considered to use branches which have a reduced maximum contingency flow then the NUF for those customers would reduce. The branch levels used by each of

the customers are outlined in Table 4-1. It is seen that for this specific network that the NUF for customers C2, C3 and C4 would reduce.

Table 4-1 Branches used by hypothetical customers by voltage level

Customer	Voltage level				
	132kV	132kV/EHV	EHV	EHV/HV	132kV/HV
C1					
C2					
C3					
C4					

Not used

Used

Table 4-2 Potential impact maximum contingency flow of branches by voltage level

Generator location	Voltage level				
	132kV	132kV/EHV	EHV	EHV/HV	132kV/HV
A					
B					
C					
D					
E					

No Change

Decrease

Increase

4.2 Impact on generation dominant network

There are two items which may impact a nodal demands NUFs after the addition of a new generator to the model in a generation dominant network.

- Does the new generation change the maximum contingency flow of the branches which the nodal demand uses ($abs[Max\ contingency\ flow]/Rating$).
- Does the new generation change the base flow on branches which the nodal demand uses ($abs[Base\ flow\ load]/base\ flow$).

Where a new generation impacts the flows on a generation dominant branch “used” by a nodal demand, since the branch is exporting generation to higher voltage levels, it is likely that the “maximum contingency flow” would be increased as there is more generation to export, increasing the NUF allocation for that asset. It is also likely that the new generation would increase “base flow” on the asset as the amount of generation being exported to the wider network is increasing. Increasing the branch “base flow” would act to decrease the NUF allocation for that asset.

Thus it is seen that adding a new generation to a network, may either increase or decrease a nodal demands NUF at each voltage level dependant on the relative network locations, network impedances, branch ratings and existing demand and generation flows in the network.

As noted earlier, when a new generator alters the maximum contingency flow of a branch the amount by which the NUF factor is altered would depend on the size of the change in flow in proportion to the branch rating. Whether a branches NUF allocation increases or decreases in a generation dominated asset would depend on the magnitude of this change combined with the magnitude of change in ‘base flow’ compared to the existing ‘base flow load’.

A new generator at location D may;

- increase the base flow on the 132 kV branches, the 132/EHV transformers, the EHV branch connecting the EHV busbars, the EHV branches supplying demand C4 and on the right hand side EHV/HV transformer supplying demand C4;
- decrease base flow on the left hand side EHV/HV transformer supplying demand C4;
- increase the maximum contingency flow on all these assets.

A new generator at location E may;

- increase the base flow on the 132 kV branches, the 132/EHV transformers, the EHV branches supplying demand C3 and the EHV/HV transformers supplying demand C3;
- decrease base flow on the EHV branch connecting the EHV busbars;
- increase the maximum contingency flow on the 132 kV branches, the 132/EHV transformers, the EHV branches supplying demand C3 and the EHV/HV transformers supplying demand C3.

As discussed in section 4.1 these effects will only impact the NUF of a particular nodal demand if that demand 'uses' the network assets. The network assets used by the demands is reproduced again in Table 4-3 and the effect on NUFs is shown in Table 4-4.

Table 4-3 Branches used by hypothetical customers by voltage level


Customer	Voltage level				
	132kV	132kV/EHV	EHV	EHV/HV	132kV/HV
C1					
C2					
C3					
C4					

Not used

Used

Table 4-4 Potential impact maximum contingency flow of branches by voltage level

Generator location	Factor	Voltage level				
		132kV	132kV/EHV	EHV	EHV/HV	132kV/HV
A	Overall NUF					
	Max Con Flow					
	Base Flow					
B	Overall NUF					
	Max Con Flow					
	Base Flow					
C	Overall NUF					
	Max Con Flow					
	Base Flow					
D	Overall NUF					
	Max Con Flow					
	Base Flow					
E	Overall NUF					
	Max Con Flow					
	Base Flow					



No Change

(Factor increases & Acts to decrease NUF) / Overall NUF decrease

(Factor increases & Acts to increase NUF) / Overall NUF increase

4.3 Summary

Adding a new generator does not change the branches ‘used’ by a nodal demand when calculating NUFs.

In demand dominant networks the new generator may decrease the maximum contingency flow on those branches which a nodal demand uses, which may generally decrease NUFs. There is a case where the maximum contingency flow on a demand dominant branch may be increased by the addition of a new generator, which would increase NUFs.

In a generation dominant network adding a new generator may increase the maximum contingency flow on branches used by a nodal demand, which may increase NUFs. The base flow on branches used by the nodal demand, however, may either increase or decrease depending on branch/load/generator locations which would either decrease or increase NUF values correspondingly. The overall combined effect on NUF factors would depend on the magnitude of MW flow changes caused compared to the branch ratings and base flow load values.

When a new generator alters the maximum contingency flow of a branch the amount by which the NUF factor is altered would depend on the size of the change in flow in proportion to the branch rating. Whether a branches NUF allocation increases or decreases in a generation dominated asset would further depend on the magnitude of this change combined with the magnitude of change in ‘base flow’ compared to ‘base flow load’.