

Attachment 2 – Existing and Proposed New Obligations

The following table describes the notices that can be issued by Distributors and the associated obligations, which are reflected in the DCP 204 legal text:

Notice	Description	Existing Obligations (which will continue to apply)	New and Additional Obligations
Advisory notice	Issued (as per clause 4.1) as an early warning of potential operational constraints on an area of the network.	n/a	The Distributor will provide an advisory notice.
Load Managed Area Notice	Issued (as per clause 5.1) as a formal notification that changes in demand may affect the security of Supply.	<ul style="list-style-type: none"> When replacing any metering equipment, Suppliers must ensure that the replacement equipment replicates the load switching times of the equipment being removed. Where the Supplier is not able to replicate the current switching times or where they wish to change those times they must consult and agree alternative arrangements with the Distributor before doing so. 	Distributors will provide Suppliers with a list of affected Metering Point Administration Numbers (MPANs) ¹ .
Security Restriction Notice (SRN)	Issued (as per clause 7.1) as a formal notification that changes in demand will affect the security of Supply.	<ul style="list-style-type: none"> As for Load Managed Area Notices, additionally: The Distributor may request that Suppliers make changes to Load Switching Regimes in the affected area to reduce the coincidence of demand in the specified area. 	<ul style="list-style-type: none"> Distributors will provide Suppliers with a list of MPANs. The Distributor may request that Suppliers make changes to the Randomised Offset Limit in the affected area to reduce the coincidence of demand in the specified area.
Emergency Security Restriction Notice ²	Issued (as per clause 8.1) as a formal notification that there is an immediate risk	As for SRNs, additionally: <ul style="list-style-type: none"> The Distributor may also issue a Compliance Notice 	<ul style="list-style-type: none"> Distributors will provide Suppliers with a list of MPANs.

¹ Currently Load Managed Area Notices are issued at postcode level.

² This notice can be served at any time i.e. it is not just restricted to Load Managed Areas or areas where an SRN has already been issued.

Notice	Description	Existing Obligations (which will continue to apply)	New and Additional Obligations
(Emergency SRN)	to the security of Supply.		<ul style="list-style-type: none"> The Distributor may request that Suppliers make changes to the Randomised Offset Limit in the affected area to reduce the coincidence of demand in the specified area.
Compliance Notice	Issued (as per clause 7.6 & 8.6)	<ul style="list-style-type: none"> Distributor requests the Supplier to change, at its own cost, Load Switching Regimes to another that shall not have a material effect on the security of supply, take such action that the Distributor considers reasonable The Distributor may, with no prior notice, de-energise metering points in order to maintain the security of supply. 	A request to adjust the Randomised Offset Limit