

Meeting Session	Interventions Working Group
Paper Reference	IWG 20220112
Action	For Information

Actions

This paper outlines the actions for the Interventions Working Group.

Open Actions

Action Ref.	Action	Owner	Update
52/01	Secretariat to make contact with the MRA to initiate conversations to address the following actions: <ul style="list-style-type: none"> Investigate whether Suppliers could be copied into D0135 flows sent to DNOs via the MOP. Investigate making the Asset Condition Code mandatory. Investigate potential for auto validation on fields such as telephone numbers, email addresses etc. 	ElectraLink	Action ongoing.

	<ul style="list-style-type: none"> Investigate adding extra data field lined for additional telephone numbers and email address within the D0135 flow 		
55/01	Secretariat to investigate the questions posed in Section 3.6 of minutes from 05.05.2021 in relation to smart meter installation calculations.	ElectraLink	Action ongoing: Secretariat to invite a member of the Energy Markets Insight team to next meeting to discuss this further. If this is not possible, a request for a document with an overview of what they could do will be actioned.
56/02	IWG members to review the items in 4.3 above (Section 2.3 of the ToR) and consider how IWG could ensure that any issues relating to the topics can be captured and addressed. What agenda items would you like to see moving forward, what data would you like to see presented?	All	Action ongoing: This action will remain open for now.
56/03	The Secretariat to investigate the various reporting in relation to Clause 30.5 within DCUSA and consider how this could be aggregated and presented at IWG.	ElectraLink	Action ongoing: Secretariat to invite a member of the Energy Markets Insight team to next meeting to discuss this further.
58/01	PM to discuss with ENA the issue regarding customer earth conductors connected into neutral connection blocks	PM	Action ongoing
60/01	SW and RH to work with Chair to draft letter to the trade associations regarding the IPC line tap connector issue. On completion, Chair to circulate to IWG members for feedback.	SW and RH	New action.
60/02	PA to investigate including a warning on the ENA website regarding the use of IPC line tap connectors	PA	New action.

Closed Actions

Action Ref.	Action	Owner	Update
59/01	PA to share the matrix that DNOs use to assess the risks relating to asbestos fuses with the group post-meeting.	PA	Action closed: PA raised the matter at the ENA STIG and noted that all DNOs have to complete their own risk assessments. All DNOs do slightly different things to mitigate the risks and therefore it would not be possible for ENA to create a proposed joint approach across all DNOs. The IWG were comfortable with this approach and the action was closed.
59/02	IWG members to share what they believe to be the main issues regarding line-tap connectors in time for the next IWG meeting (05 January 2021) for further discussion.	All	Action closed: Discussions held under agenda item 4. Further actions taken to replace 59/02.