

Meeting Session	Interventions Working Group
Paper Reference	IWG 20220302
Action	For Information

Actions

This paper outlines the actions for the Interventions Working Group.

Open Actions

Action Ref.	Action	Owner	Update
52/01	Secretariat to make contact with the MRA to initiate conversations to address the following actions: <ul style="list-style-type: none"> Investigate whether Suppliers could be copied into D0135 flows sent to DNOs via the MOP. Investigate making the Asset Condition Code mandatory. Investigate potential for auto validation on fields such as telephone numbers, email addresses etc. 	ElectraLink	Action ongoing.

	<ul style="list-style-type: none"> Investigate adding extra data field lined for additional telephone numbers and email address within the D0135 flow 		
55/01	Secretariat to investigate the questions posed in Section 3.6 of minutes from 05.05.2021 in relation to smart meter installation calculations.	ElectraLink	Action ongoing.
56/02	IWG members to review the items in 4.3 above (Section 2.3 of the ToR) and consider how IWG could ensure that any issues relating to the topics can be captured and addressed. What agenda items would you like to see moving forward, what data would you like to see presented?	All	Action ongoing.
56/03	The Secretariat to investigate the various reporting in relation to Clause 30.5 within DCUSA and consider how this could be aggregated and presented at IWG.	ElectraLink	Action ongoing.
58/01	PM to discuss with ENA the issue regarding customer earth conductors connected into neutral connection blocks	PM	Action ongoing.
60/02	PA to investigate including a warning on the ENA website regarding the use of IPC line tap connectors	PA	Action ongoing. <i>PA advised he is working to include a question within the FAQs on the ENA website.</i>
61/01	RiC to share wording from safety bulletin regarding IPC Line Tap Connectors with IWG members.	RiC	New action.
61/02	Members to send in potential agenda items and their thoughts on holding the next meeting face to face.	All	New action.

61/03	Chair to issue communication to WG members regarding the DCP 383 interim solution.	ElectraLink	New action.
--------------	--	-------------	--------------------

Closed Actions

Action Ref.	Action	Owner	Update
60/01	SW and RH to work with Chair to draft letter to the trade associations regarding the IPC line tap connector issue. On completion, Chair to circulate to IWG members for feedback.	SW and RH	Action closed. <i>Discussed under agenda item 4.</i>